

St Michel Mirror Cabinets Compliance Document

All St Michel mirrors comply with Glazing in Buildings Standard NZS4223.3.2016 - Bathroom, Ensuite and Spa Rooms Section 8.1.3 and Mirror and Glass Wall Cladding Sections 17.1 & 17.2. See below.

New Zealand Standard
Glazing in buildings
Part 3: Human impact safety requirements
NZS 4223.3.2016



8. BATHROOM, ENSUITE AND SPA ROOMS

8.1 General

Glazing in bathrooms, ensuites, or spa rooms within 2000mm of the FFL shall be safety glass.

NOTE -

(3) For mirrors in bathrooms see section 17.

17. MIRROR AND GLASS WALL CLADDING

Mirror and glass wall cladding within 2000 mm of the floor level shall be safety glass, unless the glass is fully backed and completely adhered to a solid material, in such a way that if broken the likelihood of injuries is minimised.

NOTE -

(1) Examples of full backings include walls, timber cupboards, and doors.

(2) Completely adhered means using adhesive tapes at no more than 100 mm spacing over the full height of the glazing and adhesive sealants at not less than 0.2 m² per 1 m² glazing (20% coverage).